

ADDENDUM NO. 1

City of Lakewood JBLM-North Access Improvement-Phase II City Project No. 302.0135

Date of Issue: February 24, 2022
Date of Opening: **March 1, 2022**

Notice to all Planholders:

This Addendum No. 1, containing the following revisions, additions, deletions, and/or clarifications, is hereby made a part of the Plans and Contract Provisions (Contract Documents) for the above-named project. Bidders shall take this Addendum No. 1 into consideration when preparing and submitting their bids.

Bidders shall attach this Addendum No. 1 to their copy of the Contract Provisions, and shall acknowledge receipt of this Addendum No. 1 in the space provided on the Proposal. Failure to do so may subject the Bidder to disqualification of its bid.

CONTRACT PROVISIONS

Bid Schedule

Sheet x. The Bid Schedule on the QuestCDN VBid has been changed as follows:

- Revise quantity for Item #18 "Crushed Surfacing Top Course" from 13,000 to a new quantity of 16,000.

Special Provisions

SP-108- Delete section 8-21.2. This section originally stated that the City would provide aluminum signs and that the contractor shall provide all other materials. By deleting this section, the lump sum price for "Permanent Signing" shall include all materials. THE CITY WILL NOT PROVIDE SIGNS FOR THIS PROJECT.

Appendix C Standard Plans and Details

Attached are two details which have been added to clarify the designed intent for the infiltration gallery and the flow splitter. The City does not have a sole source for these two items and welcomes comparable products provided that they meet the specifications.

For the infiltration trench, the intent is to provide 5700 FT² of infiltration trench. For the ADS product, the contractor shall provide a minimum 9" "stone backfill" per the attached detail. For the flow splitter, the City will give the weir elevation after bids open.

ALL OTHER REQUIREMENTS OF THE CONTRACT DOCUMENTS REMAIN IN EFFECT.

Troy Pokswinski

Troy Pokswinski, P.E.
City of Lakewood

Date: February 24, 2022